APPENDIX C-3

SPILL BUCKET INTEGRITY TESTING HYDROSTATIC TEST METHOD

Facility Name: Owner:						
Facility Name: Address:			Address:			
City, State, Zip Code:			City, State, Zip Code:			
Facility I.D. #:			Phone #:			
Testing Company:			Phone #: Date:			
			ouble-walled spill buckets. See PEI/RP1200, Section 6.2 for hydrostatic			
test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.						
Tank Number						
Product Stored						
Spill Bucket Capacity						
Manufacturer						
Construction	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled
Test Type	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled
Spill Bucket Type	□ Product □ Vapor	□ Product □ Vapor	□ Product □ Vapor	□ Product □ Vapor	☐ Product ☐ Vapor	□ Product □ Vapor
Liquid and debris removed from spill bucket?*	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No	□Yes □No
Visual Inspection (No cracks, loose parts or separa- tion of the bucket from the fill pipe.)	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail
Tank riser cap included in test?	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA
Is drain valve included in test?	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA
Starting Level						
Test Start Time						
Ending Level						
Test End Time						
Test Period						
Level Change						
Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column.						
Test Results	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Comments:						

*All liquids and debris must be disposed of properly.

Tester's Name _____ Tester's Signature _____