## **APPENDIX C-6**

## **OVERFILL ALARM OPERATION INSPECTION** Facility Name: Owner: Address: Address: City, State, Zip Code: City, State, Zip Code: Facility I.D. #: Phone #: Phone #: Date: Testing Company: This procedure is to determine whether the high level alarm is operational and will trigger when the tank is no more than 90% full. See PEI/RP1200, Section 7.3 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place. Tank Number Product Stored Tank Level Monitor Brand and Model 1. Tank Volume, gallons 2. Tank Diameter, inches 3. Does the overfill alarm activate in the test mode ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No at the console? 4. When activated, can the overfill alarm be heard ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No or seen while delivering to the tank? 5. After removing the probe from the tank, has it been inspected and any damaged or missing parts ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No replaced? 6. Float moves freely on the stem without binding? ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No 7. Does moving product level float up the stem ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No trigger alarm? 8. Inch level from bottom of stem when 90% alarm is triggered. 9. Tank volume at inch level in Line 8. 10. Calculate (Line 9 / Line 1) x 100 11. Is Line 10 less than 90%? ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No 12. Does the fuel float level on the console agree ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes No with the gauge stick reading? 13. Does the overfill alarm activate at any product ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No ☐ Yes ☐ No level above 90% tank capacity? If any answers in Lines 3, 4, 5, 6, 7 or 11 are "No", or Line 13 is "Yes", the system has failed the test. ☐ Pass ☐ Fail ☐ Pass ☐ Fail ☐ Pass ☐ Fail ☐ Pass ☐ Fail **Test Results Comments:**

Tester's Name \_\_\_\_\_ Tester's Signature \_\_\_\_\_