## SHEAR VALVE OPERATION INSPECTION

| | |
|---|---|
| Facility Name: | Owner |
| Address: | Address |
| City, State, Zip Code: | City, State, Zip Code: |
| Facility I.D. #: | Phone #: |
| Testing Company: | Phone #: |

This data sheet is for inspecting shear valves located inside dispensers. See PEI/RP1200 Section 10 for the inspection procedure.

| | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|
| Product Grade | | | | | | | | | |
| Dispenser ID# | | | | | | | | | |
| Shear ValveType (Product/Vapor) | | | | | | | | | |
| 1. Is the shear valve rigidly anchored to the dispenser box frame or dispenser island? | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No |
| 2. Is the shear section positioned between ½ inch above or below the top surface of the dispenser island? | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No | ☐ Yes ☐ No |
| 3. Is the lever arm free to move? | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA |
| 4. Does the lever arm snap shut the poppet valve? | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA |
| 5. Can any product be dispensed when the product shear valve is closed? | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA | ☐ Yes ☐ No ☐ NA |
| A "No" to Lines 1-4 or a "Yes" for Line 5 indicates a test failure. | | | | | | | | | |
| **Test Results** | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail |

**Comments:**

Tester's Name (print)_____ Tester's Signature _____